


Fachausschuss Elektrotechnik

der Berufsgenossenschaftlichen Zentrale
für Sicherheit und Gesundheit – BGZ
des Hauptverbandes der gewerblichen Berufsgenossenschaften



BG

Federführung:
Berufsgenossenschaft
der Feinmechanik
und Elektrotechnik

Fachausschuss Elektrotechnik, Postfach 51 05 80, 50941 Köln

INGETEAM, S. A.
C/Pintor Maeztu, 2 1º izda
31008 Pamplona
Spain

Ihre Zeichen/Nachricht vom

Unser Zeichen (Bitte stets angeben)

Bearbeiter

☎ (02 21) 37 78-

Datum

UB.010.17

PI/Ow

6312

27.03.2007

Statement of Compliance

Product: Automatic Disconnection Device

Type: INGECON SUN

Intended Use: The automatic disconnection device is used as a safety interface between the generator and the public low-voltage distribution net. It serves as a replacement for a disconnection switch which is accessible to the distribution net operator at all times.

The device is integral part of the grid-connected PV-converter INGECON SUN 2,5 TL, SUN 3,3 TL, SUN 5 TL.

Standard:
DIN V VDE V 0126-1-1
(2006-02)

"Automatic disconnection device between a generator and the public low-voltage grid"

The device fulfils the normative requirements of the above mentioned standard for the intended use.

This document is valid until:

31.12.2011

- Mehlem -
Head of Test- and
Certification Body